

UNCLASSIFIED\\FOR OFFICIAL USE ONLY**Bid Inquiry Contractor Report
All Inquiries**

Project: HHD Culverts **Review:** W912EP-18-R-0013 HP-1 (00018)
(sorted by CommentID)
Displaying 21 inquiries.

Id	Discipline	Sheet	Detail	Spec
7402653	Structural	contract (s-46)	MK. S-46-4	
<p>Comment Classification: Unclassified\\For Official Use Only (U\\FOUO)</p> <p>A clarification request for the detail MK. S-46-4 on contract sheet (S-46). In which states the sleeve material to be UNS S21800. The process of confirming the material has shown that Section 35 20 17 does not directly show the material of Axle "sleeves." There is a paragraph 2.1.1 that directs metal requirements to 05 50 15. In Section 05 50 15, paragraph 2.2.4.7 p. 10 does say "sleeves and shaft collars shall be stainless steel, type 316L. This information matches other sleeves shown on sheet (S-46) of the contract drawing.</p> <p>Please verify and provide the material type for Detail MK. S-46-4 (S-46).</p> <p>On: Apr 05 2018.</p>				
	Government Response. . See Amendment 0002 for clarification. On: May 01 2018			
	Current Request Status: Request Closed			
Information for this report is procurement sensitive.				
7402657	Structural	contract (s-46)	MK. S-46-1	
<p>Comment Classification: Unclassified\\For Official Use Only (U\\FOUO)</p> <p>A clarification request for the detail MK. S-46-1 on contract sheet (S-46). In which states the Roller Axle material to be UNS S21800. The process of confirming the material has shown that Section 35 20 17 does not directly show the material of "Roller Axles." There is a paragraph 2.1.1 that directs metal requirements to 05 50 15. In Section 05 50 15, paragraph 2.2.4.3 p. 9 does say "Roller Axle, Shaft, Pins" to be UNS S20910. This information does not match the detail on sheet (S-46) of the contract drawing.</p> <p>Please verify and provide the material type for Detail MK. S-46-1 (S-46).</p> <p>On: Apr 05 2018.</p>				
	Government Response. . Please see amendment 0002 for revision. On: May 01 2018			
	Current Request Status: Request Closed			
Information for this report is procurement sensitive.				
7411448	Civil	G-03		01 11 00
<p>Comment Classification: Unclassified\\For Official Use Only (U\\FOUO)</p> <p>please confirm the only access to the project site is thru US-78 and all borrow and other deliverables will travel over the dike crest access road.</p> <p>On: Apr 11 2018.</p>				
	Government Response. . Construction access is specified in Section 01 11 00 and as shown on drawing G-03. On: Apr 17 2018			
	Current Request Status: Request Closed			
Information for this report is procurement sensitive.				
7411459	Civil		drawing notes	G-3
<p>Comment Classification: Unclassified\\For Official Use Only (U\\FOUO)</p> <p>What improvements is the USACE expecting at the US-78 Intersection and/or Acceleration lanes? Further please identify what bid item(s) this activity will be paid?</p> <p>On: Apr 11 2018.</p>				
	Government Response. . Please reference specification section 01 11 00, paragraph 1.3.3, "The contractor is responsible for obtaining and complying with all requirements of State, County, and other jurisdictional agencies for permits, criteria and use including requirement in EM-385.1.1."			
	Please reference CLIN 0001 ACCESS. On: May 01 2018			

Current Request Status: Request Closed				
Information for this report is procurement sensitive.				
7411473	General			form 1442 solicitation offer award
Comment Classification: Unclassified\\For Official Use Only (U\\FOUO)				
Consider extending the bid date deadline to a later date at minimum least a week. Please avoid Monday(s) as a deadline day for bid; may we suggest Tuesday May 01 2018.				
On: Apr 11 2018.				
Government Response. . The new Bid Opening date is changed from 23 April 2017 to 27 April 2017. This information will be captured in Amendment 0001 that will be issued on 17 April 2018. On: Apr 17 2018				
Current Request Status: Request Closed				
Information for this report is procurement sensitive.				
7411481	Civil	C-01 and S-63		
Comment Classification: Unclassified\\For Official Use Only (U\\FOUO)				
please clarify tail water cofferdam elevations. drawings sheet C-01 and S-63 top tail water cofferdam elevations conflict as one sheet indicates +17 and the other +13				
On: Apr 11 2018.				
Government Response. . Please see amendment 0001. The cofferdam top elevation on drawing S-63 has been revised to El 17. On: Apr 17 2018				
Current Request Status: Request Closed				
Information for this report is procurement sensitive.				
7411486	Contracting			00010A bid items
Comment Classification: Unclassified\\For Official Use Only (U\\FOUO)				
please review line item 0005 COFFERDAM ARMORING (ESTIMATED QUANTITY). please verify is not a bid item, if otherwise please revise bid form with units and quantity.				
On: Apr 11 2018.				
Government Response. . Please see amendment 1 where the bid sheet has been revised. Amendment 0001 will issue today 17 April 2018. On: Apr 17 2018				
Current Request Status: Request Closed				
Information for this report is procurement sensitive.				
7411488	Contracting			01 22 00 measurement and payment 1.5.5
Comment Classification: Unclassified\\For Official Use Only (U\\FOUO)				
SECTION 01 22 00 measurement and payment 1.5.5 Cofferdam Armoring (Line Item 0005). this does not appear on the bid form; please advise if this line is to be deleted.				
On: Apr 11 2018.				
Government Response. . Please see amendment 0001 where the bid sheet and section 01 22 00 Measurement and payment section is revised. Amendment 0001 will issue today 17 April 2018 On: Apr 17 2018				
Current Request Status: Request Closed				
Information for this report is procurement sensitive.				
7415926	Contracting			00010A
Comment Classification: Unclassified\\For Official Use Only (U\\FOUO)				
Line item 0005 Cofferdam Armoring on the Line Item and Pricing Schedule does not have a quantity, unit, or line for total dollars. Is the intent to provide pricing for line item 0005? If so please provide a quantity, unit and blank line for the dollar amount on the Pricing Schedule				
On: Apr 13 2018.				
Government Response. . Please see amendment 0001 where the bid sheet and section 01 22 00 Measurement and payment section is revised. Amendment 0001 will issue today 17 April 2018 On: Apr 17 2018				
Current Request Status: Request Closed				
Information for this report is procurement sensitive.				

7415945	Contracting			00100A
Comment Classification: Unclassified\\For Official Use Only (U\\FOUO)				
Will a scanned copy of the Letter of Commitment of Key Subcontractor's submitted with the "Original" Proposal volume be acceptable?				
On: Apr 13 2018.				
	Government Response. . Yes, A scanned copy will be acceptable On: Apr 17 2018			
	Current Request Status: Request Closed			
Information for this report is procurement sensitive.				
7415962	Contracting	00800-5		00800
Comment Classification: Unclassified\\For Official Use Only (U\\FOUO)				
Please confirm that the Subcontracting Plan is not required to be submitted with the offer and may be submitted upon request by the Contracting Officer?				
On: Apr 13 2018.				
	Government Response. . The Subcontracting Plan IS required at the time your proposal is due. Amendment 0002 will revise the spec section. On: Apr 17 2018			
	Current Request Status: Request Closed			
Information for this report is procurement sensitive.				
7419611	Construction Management			00010A-4
Comment Classification: Unclassified\\For Official Use Only (U\\FOUO)				
The original Advertisement for this proposal was May 9, 2018. The Notification of proposal on FBO.gov states bids are due April 24, 2018. The Solicitation Form SF 1442 states the proposal is due April 23, 2018. However, the deadline for submitting questions is close of business on Friday, April 20, 2018. Please verify the Proposal Due Date, and if it is 1 work day prior to the RFI deadline I would like to request an extension to properly distribute the answers to outstanding questions. Thank you.				
On: Apr 16 2018.				
	Government Response. . The receipt of proposal due date is 23 April 2018. However an extension of receipt of proposals is extended the 27 April 2018. This information will be confirmed via Amendment 0001 that will be issued today 17 April 2018. On: Apr 17 2018			
	Current Request Status: Request Closed			
Information for this report is procurement sensitive.				
7421827	Contracting			00800A Wage determinations
Comment Classification: Unclassified\\For Official Use Only (U\\FOUO)				
What labor codes and wage rates are required by wage decisions for 1) rebar placement (rodbusters) 2)Concrete form carpenters 3) Concrete finishers; the provided Wage decision in section 00800A does not identify labor codes for these trades?				
On: Apr 18 2018.				
	Government Response. . As noted on Section 00800A-2, the Wage Decision is limited in scope. Any other work classifications required to complete the project will be added through the DOL conformance process. DOL AAM 213 and Frequently Asked Questions (FAQ) are attached for informational purposes and outline the "conformance process." Additional classifications required should be requested through this process as soon as possible.			
	DOL AAM 213 FAQ's will be uploaded as an attachment on FBO for information only. On: May 01 2018			
	Current Request Status: Request Closed			
Information for this report is procurement sensitive.				
7421834	Contracting			reference question 7415962 section 00700 clause 52.219-9
Comment Classification: Unclassified\\For Official Use Only (U\\FOUO)				
please clarify what volume of the proposal Subcontracting plan is to be incorporated in? reference question 7415962 and section 00700 clause 52.219-9				
On: Apr 18 2018.				
	Government Response. . Please see Amendment 0004 to be posted to FBO today. On: May 01 2018			
	Current Request Status: Request Closed			
Information for this report is procurement sensitive.				

7424518	Structural	S-63 and C-01	1- S-63	
Comment Classification: Unclassified\\For Official Use Only (U\\FOUO) The landside cofferdam coordinates shown on DWG C-01 calculate the total length of the cofferdam to be approximately 73.8'. This would be 32 units of PZC-26. Structural DWG S-63 indicate there are 59 units of PZC-26 sheet piles, which would make the overall length of the cofferdam approximately 137'. Please confirm the overall length of the cofferdam. On: Apr 19 2018.				
	Government Response. . Please see amendment 0003 for revised drawing S-63. On: May 01 2018			
	Current Request Status: Request Closed			
Information for this report is procurement sensitive.				
7428697	Contracting			01100
Comment Classification: Unclassified\\For Official Use Only (U\\FOUO) Specification Section 01 11 00 (1.3.5.1) requires the contractor to maintain "a pump utilization log in order to track the number of hours of pump usage, as well as the dates and times the pumping unit (or units) was requested to be operated." However, under Section 00010A (Line Items and Pricing Schedule), Bid Items 0039 (Bypass Pump(s) Operation and 0040 (Bypass Pump(s) Standby Time has listed this pay item as "Job" which would be a lump sum amount. Contractor requests this pay item be changed to "hourly" which would allow accurate compensation for the Bypass Pumping portion of the work. On: Apr 20 2018.				
	Government Response. . Bid ass specified. On: May 01 2018			
	Government Response. . The text below appends or clarifies ALL previous replies. Bid as specified. On: May 01 2018			
	Current Request Status: Request Closed			
Information for this report is procurement sensitive.				
7428701	Contracting			00010A
Comment Classification: Unclassified\\For Official Use Only (U\\FOUO) Bid form line item 0025 Embankment Fill. The quantity of 33,760 cy appears to be low even after deducting for conc, drainage blanket, chimney and bentonite. Please verify that the quantity is correct. On: Apr 20 2018.				
	Government Response. . Bid ass prescribed. On: May 01 2018			
	Government Response. . The text below appends or clarifies ALL previous replies. Bid as specified. On: May 01 2018			
	Current Request Status: Request Closed			
Information for this report is procurement sensitive.				
7428717	Contracting			0010A
Comment Classification: Unclassified\\For Official Use Only (U\\FOUO) The Line Items and Pricing Schedule do not include line items for; ? Payment and Performance Bonds ? Contractor Mobilization Confirm bidders to include these cost in "Access" line items. On: Apr 20 2018.				
	Government Response. . Cost for those items will be distributed amongst all clins. On: May 01 2018			
	Current Request Status: Request Closed			
Information for this report is procurement sensitive.				
7428722	Contracting			0010A
Comment Classification: Unclassified\\For Official Use Only (U\\FOUO) Confirmed payments will be made for approved materials suitably stored on site including rip-rap and embankment fill. On: Apr 20 2018.				
	Government Response. . Refer to Specification Section 01 22 00 1.4 Payment Procedures. On: May 01 2018			
	Current Request Status: Request Closed			

Information for this report is procurement sensitive.

7428733	Contracting			012200
----------------	-------------	--	--	--------

Comment Classification: **Unclassified\\For Official Use Only (U\\FOUO)**

General decision number: FL180135 01/05/2018

FL135 "Heavy" is inadequate for culvert construction projects. Since the bidders cannot request wage rates for bidding purposes, please provide wage rates for the following:

- ? Concrete Form Carpenters
- ? Concrete Laborers
- ? Concrete Finishers
- ? Welders
- ? Iron Workers (Concrete Reinforcing Steel)
- ? Crane Operators

On: Apr 20 2018.

Government Response. . As noted on Section 00800A-2, the Wage Decision is limited in scope. Any other work classifications required to complete the project will be added through the DOL conformance process. DOL AAM 213 and Frequently Asked Questions (FAQ) are attached for informational purposes and outline the "conformance process." Additional classifications required should be requested through this process as soon as possible.

DOL AAM 213 FAQ's will be uploaded as an attachment on FBO for information only. On: May 01 2018

Current Request Status: **Request Closed**

Information for this report is procurement sensitive.

7437893	Civil	G-04		
----------------	-------	------	--	--

Comment Classification: **Unclassified\\For Official Use Only (U\\FOUO)**

Reference Plan Sheet G-04; the soil borings / Muck Probes indicate extensive sediment at locations HHD-HP1-16,17,,and 18. However, there is no found requirement for contractor to remove the muck at these 3 locations. Please advise.

On: Apr 26 2018.

Government Response. . Bid as specified. On: May 01 2018

Current Request Status: **Request Closed**

Information for this report is procurement sensitive.

Report Complete

UNCLASSIFIED\\FOR OFFICIAL USE ONLY

Patent 11/892,984 ProjNet property of ERDC since 2004.