



SOUTH FLORIDA WATER MANAGEMENT DISTRICT SOLICITATION ADDENDUM

South Florida Water Management District
Attn: Procurement Bureau
B-1 Building, 2nd Floor West
3301 Gun Club Road
West Palm Beach, FL 33406

REQUEST FOR BID (RFB) NUMBER: 6000000676

ADDENDUM NUMBER: 1

DATE: June 14, 2017

PROJECT TITLE: C-44 RESERVOIR/STA PROJECT, TIWCD PERMANENT PUMP STATION, MARTIN COUNTY, FL

DEADLINE FOR RFB 6000000676 REMAINS JUNE 21, 2017 @ 2:30 P.M.

This **ADDENDUM NO. 1** is issued for the purpose of providing the information below.

1. **DRAWINGS:**

1. Delete Drawing No. C0007 originally provided in the solicitation and replace with the attached Drawing No. C0007, sheet 13 of 23, Rev. #1, provided as part of Addendum No. 1.

2. **QUESTIONS AND ANSWERS:** Attachment 1 to this Addendum No. 1 contains the list of Questions and Answers.

Please direct any questions to the Procurement Representative specified below at (561) 682-2521 or bcantrel@sfwmd.gov

Bonnie Cantrell
Lead Contract Specialist
Procurement Bureau

ATTACHMENT 1
RFB 6000000676- ADDENDUM: 1
QUESTIONS AND ANSWERS

1. **Question:** My question is about the 3000 Gal fuel tank that needs to be relocated from Site 1 to Site 2. Does the tank contain fuel? If so, what quantity of volume and is it reusable? And can it be pumped into another tank onsite or does it need to be disposed of?

Answer: Refer to Specification Section 01510 – TEMPORARY UTILITIES AND FACILITIES, Paragraph 3.02.B.5 and Specification Section 02050 – DEMOLITION, Paragraph 3.01.G.

2. **Question:** I have a question about the pumps being installed at the TIWCD Pump Station and I did not see details in the plans. Have the pumps been purchased already? If so, can you provide the bid information or number on them. If the pumps have not been purchased, when will they be put out for bid?

Answer: The pumps for the TIWCD Permanent Pump Station have not been acquired and no related bid information is available. The pumping system for the TIWCD Permanent Pump Station is to be provided by the CONTRACTOR as part this RFB. Refer to Specification Section 11063 IRRIGATION PUMPING SYSTEMS, PART 2 – PRODUCTS, for the pumping system requirements.

3. **Question:** The specification sections, and drawings listed below, conflict with each other. Please clarify what type of fill material is to be used to backfill the pipes.

SECTION 02200-1, 1.03 DEFINITIONS B. Unclassified Fill: “Unclassified backfill shall be placed where select backfill is not shown or noted on the Drawing.”

SECTION 02200-4, 3.03 BACKFILLING: B. Structure Backfill: “The CONTRACTOR shall backfill using select backfill.”

SECTION 02221-2, 3.05 BACKFILLING TRENCHES: B. “Pipe trenches shall be backfilled with select fill”

DRAWING NO C0007, The details for Discharge and Suction Pipe shows backfill above the bedding to be unclassified backfill.

Answer: Refer to Drawing No. C0007, Item #1, Drawings page 1 of this Addendum No. 1.